

### Disposition of Review Comments Log

**Project Name:** Welfare Facility Design

**Project #:** AA-1234

**Contract #:** K98765

**Task #:** 2

**Third Party Consultant:** XYZ Consultants

**Deliverable:** 60% Design Documents

**Date:** 8/1/2018

Number	Reviewer (Initials)	Reviewer's Company (Abbreviate)	Sheet, Page, or Section Number	Reviewer Comment	Responding Designer (Initials)	Designer Comment	Final Resolution	Final Resolution Comment Date	Status
001	MA	Metra	A-1	The square footage for the storage room is inadequate. Should be 100 SF.	DD	Disagree - The design criteria states that the storage room only needs to be 50 SF.	Resolved at meeting on 8/5/2018. Storage room will remain at 50 SF.	8/6/2018	Closed
002	MA	Metra	Sec. 024100, 1.01, A	The word "demolition" is misspelled.	DD	Agree	Corrected	8/6/2018	Closed